



MARK B HORTON, MD, MSPH
Director

State of California—Health and Human Services Agency
California Department of Public Health



ARNOLD SCHWARZENEGGER
Governor

November 12, 2009

Mr. Dan Loy, President
Nova Water Technologies, LLC
P.O. Box 23523
Tampa, FL 33623

Subject: Use of the Nova Ultrascreen Filter® to Comply with
California Water Recycling Criteria

Dear Mr. Loy

By submittal dated September 14, 2009, Carollo Engineers requested Departmental review of the Nova Ultrascreen Filter® as an acceptable filtration technology for compliance with the existing State of California Water Recycling Criteria (Title 22). Accompanying the submittal was a performance data report dated September 2009, which outlines the performance evaluation findings of this filtration process. The filtration performance data outlined in the report indicates the filter's ability to reliably meet the existing turbidity performance requirements outlined in Title 22 at incremental loading rates of 6, 8, 12 and 16 gpm/ft².

Based on a review of the materials submitted, the Department conditionally accepts the use of the Nova Ultrascreen Filter® as a filtration technology for use in compliance with the existing California Water Recycling Criteria.